

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 72180199

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
Paul Ng

Unser Zeichen *Our Reference*
-AK-31880019 002

Ausstellungsdatum *Date of Issue*
31.01.2018
(day/mo/yr)

Genehmigungsinhaber *License Holder*
GE Power Electronics, Inc.
601 Shiloh Rd.
Plano TX 75074
USA

Fertigungsstätte *Manufacturing Plant*
Lineage Power Matamoros
S.A. de C.V.
Poniente 2 No. 3 entre Norte
7 Limite del Fraccionamiento
Ciudad Industrial (CIMA)
87499 Matamoros, Tamaulipas, TAMPS
Mexico

Prüfzeichen *Test Mark*



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1234501541

Geprüft nach *Tested acc. to*
EN 60950-1:2006+A11+A1+A12+A2

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Power Supply AC-DC Rectifier

Model Designation: Cy12500H3C380TEZxxx 7
(x= "-", 0-9, A-Z; not safety-relevant;
y= C, H)

Rated Voltage: 3 AC 400/480V, 50/60Hz
Rated Current: 16A
Protection Class: I
Output Ratings DC: 360-400V/28,9-34,7A;
10417-12500W; 12V/1,8A

Special Remarks: To be installed according to the licensee's
installation instructions.

7

ANLAGE (Appendix): 1, 1-4



Zertifizierungsstelle

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Martin Nagel